## ORGANIC IMPURITIES IN FINE AGGREGATE FOR CONCRETE FOP FOR AASHTO T 21

03

04

05

#### 02 Scope

This method of test covers a procedure for an approximate determination of the presence of injurious organic compounds in natural sands, which are to be used in cement mortar or concrete.

In this procedure a sample of fine aggregate is placed in a sodium hydroxide solution and shaken. The following day the color of the supernatant solution is compared with a standard color. If the color is darker than the standard, the fine aggregate should not be used without further investigation.

#### **Significance**

Aggregates are potentially harmful if they contain compounds known to react chemically with portland cement and other constituents of the portland-cement concrete, and produce undesirable properties such as expansion of the paste or aggregates, reduction in strength, etc.

Organic impurities may delay setting and hardening of concrete, may reduce strength gain, and in unusual cases may cause deterioration.

#### **Apparatus**

- **Balance or Scale:** Capacity of 1000 g and sensitive to 0.1 g
- **Bottles:** Clear (colorless), graduated glass bottles having a capacity of 8 to 16 fl. oz. with water tight stoppers or caps. Outside diameter (measured along the line of sight used for color comparison) 1.5 in. to 2.5 in.
- Glass Color Standard: Glass color plate with organic plate numbers 1-5. (Organic plate no. 3 to be equal to Gardener Color Standard No. 11)

#### Reagent and Standard Color Solution

- **Reagent Sodium Hydroxide Solution:** 3 parts NaOH to 97 parts water by mass.
- **Standard Color Solution:** Solution of reagent grade Potassium Dichromate dissolved in



06

T21\_stu Laboratory 2- 1 2005

LABORATORY UDOT/TTQP AASHTO T21

07

08

sulfuric acid. Solution to be freshly made (within 2 hours), equal to Organic Color No. 3.

Sampling

Obtain a representative sample of fine aggregate according to the FOP for AASHTO T 2.

**Test Sample** 

Using the FOP for AASHTO T 248, obtain a test sample weighing approximately 450 g from the sand to be tested. If sample drying prior to testing is necessary, only air-drying shall be allowed.

**Procedure** 

1. Fill a bottle to the 130 mL (4½ ounce) mark with the sand to be tested.

2. Add a sufficient amount of the 3 per cent sodium hydroxide solution to bring the level of the liquid, after shaking, to the 200 mL (7 ounce) mark.

3. Stopper the bottle and shake vigorously to eliminate air bubbles.

4. Allow the bottle to stand undisturbed for 24 hours. (Do not place bottle in direct sunlight).

5. At the end of the 24-hour standing period compare the color of the supernatant liquid against one of the reference color standards.

Report

• Report on standard agency forms.

• Standard solution method: Record whether the supernatant liquid is lighter, darker, or equal in color to that of the reference standard.

 Glass color plate method: Record the organic plate number that is nearest the color of the supernatant liquid.

09 10 11

12

T21\_stu Laboratory 2- 2 2005

LABORATORY UDOT/TTQP AASHTO T21

## Tips!

• Be cautious handling reagents. They are caustic and may cause serious skin or eye injury.

 Be careful handling sample bottle when color comparison is made. Disturbance of the contents may cause the liquid to become clouded, making color comparison difficult.

T21\_stu Laboratory 2- 4 2005

#### **REVIEW QUESTIONS**

1.	From the sample that was obtained according to AASHTO T 2, how much material is
	generally required to perform this test?

- 2. According to this FOP, how may the sample be dried?
- 3. After addition of the NaOH solution, what must be done?
- 4. Describe the color comparison procedure.

Laboratory 2-4

T21\_rev

September 2004

### PERFORMANCE EXAM CHECKLIST

# ORGANIC IMPURITIES IN FINE AGGREGATES FOR CONCRETE FOP FOR AASHTO T 21

Participant Name:			Exam Date:			
		Proce	dure			
1. 2. 3. <b>Pro</b> 1. 2. 3. 4.	If sample is dried Sample weighs appocedure Sand added to the NaOH solution ad Bottle stoppered a Bottle, containing	ample of appropriate m prior to testing, is it drie proximately 450 g?  4½ oz. (130 ml) level i dded to the 7 oz. (200 m and shaken vigorously? sample, allowed to star made against color star	ed only by n the bottle L) level? ( nd for 24 h	e? 7 oz. after shaking)?		
1. 2.	<ul><li>b. Supernatant so</li><li>Glass Color Stand</li><li>a. Proper Garder</li></ul>	olution Method ly made (within two ho olution color lighter or c	larker than	_ _		
Co	mments:	First attempt: (Pass/Fail	)	Second attempt: (Pass/Fa	il)	
Evo	aminer Signature		V	WAOTC #·		

T21\_pr Laboratory 2- 6 October 2004